



---

**west virginia department of environmental protection**

---

Division of Air Quality  
601 57<sup>th</sup> Street SE  
Charleston, WV 25304  
Phone: (304) 926-0475 • FAX: (304) 926-0479

Earl Ray Tomblin, Governor  
Randy C. Huffman, Cabinet Secretary  
[www.dep.wv.gov](http://www.dep.wv.gov)

October 14, 2016

CERTIFIED MAIL  
91 7199 9991 7035 6610 3856

Greg Darby, President  
PO Box 968  
Beckley, WV 25802

RE: Little General Store, Inc.  
Facility #2495  
Permit Application G65-C560  
Plant ID No. 081-00269

Dear Mr. Darby:

Your application for a permit as required by Section 5 of 45CSR13 - "Permits for Construction, Modification, Relocation and Operation of Stationary Sources of Air Pollutants, Notification Requirements, Temporary Permit, General Permit, and Procedures for Evaluation" has been approved. The enclosed permit G65-C560 is hereby issued pursuant to Subsection 5.7 of 45CSR13. Please be aware of the notification requirements in the permit which pertain to commencement of construction, modification, or relocation activities; startup of operations; and suspension of operations.

The source is not subject to 45CSR30.

In accordance with 45CSR22 - Air Quality Management Fee Program, the permittee shall not operate nor cause to operate the permitted facility or other associated facilities on the same or contiguous sites comprising the plant without first obtaining and having in current effect a Certificate to Operate (CTO). Such Certificate to Operate (CTO) shall be renewed annually, shall be maintained on the premises for which the Certificate has been issued, and shall be made immediately available for inspection by the Secretary or his/her duly authorized representative.

Any person whose interest may be affected, including, but not necessarily limited to, the applicant and any person who participated in the public comment process, by a permit issued, modified or denied by the Secretary may appeal such action of the Secretary to the Air Quality Board pursuant to article one [§§22B-1-1 et seq.], Chapter 22B of the Code of West Virginia. West Virginia Code §§22-5-14.

Should you have any questions or comments, please contact me at (304) 926-0499, extension 1212.


Sincerely,

Thornton E. Martin Jr.  
Permit Engineer

*West Virginia Department of Environmental Protection*  
*Earl Ray Tomblin*      *Division of Air Quality*  
*Governor*

*Randy C. Huffman*  
*Cabinet Secretary*

## Class I General Permit G65-C Registration to Construct



for the  
Prevention and Control of Air Pollution in regard to the  
Construction, Modification, Relocation, Administrative Update and  
Operation of Emergency Generators

*The permittee identified at the facility listed below is authorized to  
construct the stationary sources of air pollutants identified herein in accordance  
with all terms and conditions of General Permit G65-C.*

**G65-C560**

Issued to:  
**Little General Store, Inc.**  
Facility #2495  
081-00269

  
\_\_\_\_\_  
*William F. Durham*  
Director

*Effective: October 14, 2016*

This Class I General Permit Registration does not affect any other 45CSR13 permits.

Facility Location: Ghent/Flat Top, Raleigh County, West Virginia  
Mailing Address: PO Box 968, Beckley, West Virginia 25802  
Facility Description: Emergency Generator  
SIC Codes: 5541  
UTM Coordinates: 489.79 km Easting • 4163.23 km Northing • Zone 17  
Registration Type: Construction  
Description of Change: Permit operation of an emergency generator used during power outages.

*Any person whose interest may be affected, including, but not necessarily limited to, the applicant and any person who participated in the public comment process, by a permit or registration issued, modified or denied by the Secretary may appeal such action of the Secretary to the Air Quality Board pursuant to article one [§§ 22B-1-1 et seq.], Chapter 22B of the Code of West Virginia. West Virginia Code §22-5-14.*

---

*The source is not subject to 45CSR30.*

---

*Unless otherwise stated WVDEP DAQ did not determine whether the permittee is subject to an area source air toxics standard requiring Generally Achievable Control Technology (GACT) promulgated after January 1, 2007 pursuant to 40 CFR 63, including the area source air toxics provisions of 40 CFR 63, Subpart HH and 40 CFR 63, Subpart ZZZZ.*

**All registered facilities under Class I General Permit G65-C are subject to Sections 1.0, 2.0, 3.0, and 4.0.**

The following sections of Class I General Permit G65-C apply to the registrant:

Section 5	Reciprocating Internal Combustion Engines (R.I.C.E.)	<input checked="" type="checkbox"/>
Section 6	Tanks	<input checked="" type="checkbox"/>
Section 7	Standards of Performance for Stationary Compression Ignition Internal Combustion Engines (40CFR60 Subpart IIII)	<input checked="" type="checkbox"/>
Section 8	Standards of Performance for Stationary Spark Ignition Internal Combustion Engines (40CFR60 Subpart JJJJ)	<input type="checkbox"/>

### Emission Units

Emission Unit ID	Emission Unit Description (Make, Model, Serial No.)	Year Installed	Design Capacity (Bhp/rpm)
EG-1	Caterpillar, 1996, Ser. No. 5YFO3072	2013	305/1800
T-01	Fuel Tank, 265 gallons, #2FO	2013	N/A

### Emission Limitations

Source ID#	Nitrogen Oxides		Carbon Monoxide		Particulate Matter < 10 microns	
	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr
EG-1	4.64	1.16	5.71	1.43	0.26	0.065